

2014 NEC Section	Current Mesquite - 2011 National Electrical Code Amendment	2014 NEC Recommended Amendments	BO Recommendation
This table does not list amendments in the current code that are being retained in the proposed ordinance.			
300.11	<p>Amend by adding the following exception to Section 300.11 to read as follows:</p> <p>Exception: Ceiling grid support wires may be used for structural supports when the associated wiring is located in that area, not more than two raceways or cables supported per wire, with a maximum nominal metric designation 16 (trade size 1/2").</p>		<p>Approve Stay consistent with all other jurisdictions</p>